

1 General

1.1 **SUMMARY**

- .1 **General Requirements:** Conform with requirements of all Sections of Division 01, General Requirements, as it applies to the work of this Section.

1.2 **REFERENCES**

- .1 ASTM C957 – Specification for High Solids Content, Cold Liquid-Applied-Elastomeric Waterproofing Membrane with Integral Wearing Surface.
- .2 ASTM C1127 – Standard Guide for Use of High Solids Content, Cold Liquid Applied Elastomeric Waterproofing Membrane with an Integral Wearing Surface.

1.3 **QUALITY ASSURANCE**

- .1 **Qualifications:** Perform work of this Section only by an applicator of recognized standing who has adequate plant, equipment, and skilled workers to perform it expeditiously, and is known to have been responsible for satisfactory applications similar to that specified during a period of minimum five years.
- .2 **Mock-up:** Provide on-site areas minimum 3 m², of each coating material with slip resistance specified, for review. Over-coat unacceptable mock-ups with acceptable coating systems.
- .3 **Pre-Installation Meetings:** Before work commences, arrange for a site meeting, at which conditions of surfaces and possible adaptations to suit, and use of materials and application procedures shall be discussed between Contractor, Waterproof Coating Subcontractor, Consultant, and representatives of material manufacturers.

1.4 **ACTION SUBMITTALS**

- .1 **Product Data:** For each type of product. Include manufacturer's technical data, application instructions, and recommendations for each traffic coating component required.
- .2 **Sustainable Design Submittals:**
- .1 **Laboratory Test Reports:** For traffic coating products, indicating compliance with requirements for low-emitting materials.
- .3 **Samples for Initial Selection:** For each type of exposed finish required.
- .4 **Samples for Verification:** For each traffic coating system required, 6 inches (150 mm) square, applied to a rigid backing by Installer for this Project.

1.5 **INFORMATIONAL SUBMITTALS**

- .1 **Installer Certificates:** Signed by manufacturer certifying that installers comply with specified requirements.
- .2 **Material Certificates:** For each traffic coating component, from manufacturer.
- .3 **Material Test Reports:** For each traffic coating system, by a qualified testing agency.

DURABOND TECHNICAL COATINGS LIMITED

The text and format of this guide Specification is provided by Durabond Technical Coatings Limited as information and is Not liable in any way for any revisions or the use of this Guide Specification by any end user. A qualified design professional should review and edit the document to suit project requirements. For more information call Durabond Technical Coatings Limited at 1-877-DURABOND (387-2266).

1.6 **CLOSEOUT SUBMITTALS**

- .1 Maintenance Data: For traffic coating to include in maintenance manuals.

1.7 **DELIVERY, STORAGE, AND HANDLING**

- .1 Package, seal and label each coating material to show manufacturer's and product name, and colour.
- .2 Store materials at site in an area specifically set aside for purpose that is locked, ventilated, and maintained at a minimum temperature of 16°C.
- .3 Ensure that health and fire regulations are complied with in storage area, and during handling and application.

1.8 **AMBIENT REQUIREMENTS**

- .1 Broadcast anti-slip is required.
- .2 Apply traffic coating only:
 - .1 With surface temperatures recommended by manufacturer. Do not apply traffic coating to damp, icy or wet substrate or during snow, rain, fog, or mist.
 - .2 In temperatures 3 degrees C above the dew point.
 - .3 When no materials/substances that may impede adhesion is present (including ice).
 - .4 Suspended slab applications with moisture content less than 4% by weight
- .3 Place cloths and other disposable materials that are a fire hazard in closed metal containers and remove from building every night.
- .4 Post "No Smoking" signs and ensure that spark-proof electrical equipment is used in areas where inflammable materials are being applied.

2 Products

2.1 **MATERIALS**

- .1 Each material used in the application of each traffic coating system shall be as recommended or manufactured by the supplier of the traffic coating system.
- .2 Traffic Coating and Base: Combining primer, waterproof membrane and Wear coat with non-slip surface texture and topcoat. Minimum 4.44 mm (175 mils) thick, Class A fire resistance or better, Dur-A-Fast Primer by Durabond Technical Coatings Limited.
 - .1 Primer: two component, polyurethane modified methyl methacrylate (PUMA) primer
 - .1 Percent solids: 100 percent.
 - .2 Volatile Organic Content (VOC): zero (0) g/L.
 - .3 Tensile Modulus: ASTM D638-86; 1,280 psi.

DURABOND TECHNICAL COATINGS LIMITED

The text and format of this guide Specification is provided by Durabond Technical Coatings Limited as information and is Not liable in any way for any revisions or the use of this Guide Specification by any end user. A qualified design professional should review and edit the document to suit project requirements. For more information call Durabond Technical Coatings Limited at 1-877-DURABOND (387-2266).

- .4 Elongation: ASTM D638-86; 0.8%.
- .5 Mar Resistance: ASTM D5178; 1.0 kg.
- .6 Shore A Hardness: ASTM D2240; 85.
- .7 Water Vapour Permeance: ASTM E96; 0.20 Perm In. (0.0025 ng/ Pa-s-m²).
- .2 Waterproof Membrane: two component, 100 percent solids, solvent free, high solids, self-priming, polyurethane modified methyl methacrylate waterproof membrane, Dur-A-Fast Membrane by Durabond Technical Coatings Limited. .
 - .1 Percent solids: 100 percent.
 - .2 Volatile Organic Content (VOC): 0 g/L.
 - .3 Tensile Modulus: ASTM D638-86; 1,500 psi.
 - .4 Tear Strength: ASTM D624 Die C; 92 lb/ In in
 - .5 Elongation: ASTM D638; 520 percent.
 - .6 Flexural Modulus: ASTM D522; 2 mm film passes 12 mm mandrel.
 - .7 Low Temperature Flexibility: 1/8" mandrel at 26 degrees C; pass.
 - .8 Water Absorption: ASTM D570; <0.1 percent.
 - .9 Shore A Hardness: ASTM D2240; 85.
 - .10 Pull Off Strength: ASTM D4541; 3.35 MPa (480 psi) over primed concrete surface.
 - .11 Water Vapour Transmission: ASTM E96, Procedure B; 0.029 g/hr-m² (0.05 grains/ hr-pi²).
 - .12 Water Vapour Permeability: ASTM E96; 0.20 Perm In. (0.0025 ng/Pa-s-m²).
 - .13 Water Vapour Permeance: ASTM E96; 0.20 Perm In. (0.0025 ng/ Pa-s-m²).
- .3 Traffic Bearing Wearcoat: two component, solvent free, high solids polyurethane modified methyl methacrylate pigmented wearcoat coating, Dur-A-Fast Wearcoat by Durabond Technical Coatings Limited.
 - .1 Percent solids: 100 percent.
 - .2 Volatile Organic Content (VOC): zero (0) g/L.
 - .3 Tensile Modulus: ASTM D638-86; 1,500 psi.
 - .4 Tear Strength: ASTM D624 Die C; 130 lb/ In).
 - .5 Elongation: ASTM D638-86; 200 percent.

DURABOND TECHNICAL COATINGS LIMITED

The text and format of this guide Specification is provided by Durabond Technical Coatings Limited as information and is Not liable in any way for any revisions or the use of this Guide Specification by any end user. A qualified design professional should review and edit the document to suit project requirements. For more information call Durabond Technical Coatings Limited at 1-877-DURABOND (387-2266).

- .6 Water Absorption: ASTM D570; 0.15 percent.
 - .7 Shore Hardness: ASTM D2240; 95.
 - .8 Water Vapour Permeance: ASTM E96; 0.20 Perm In. (0.0025 ng/ Pa-s-m²).
 - .4 Traffic Bearing Sealcoat: two component, solvent free, high solids polyurethane modified methyl methacrylate pigmented sealcoat coating, Dur-A-Fast Wearcoat by Durabond Technical Coatings Limited.
 - .1 Percent solids: 100 percent.
 - .2 Volatile Organic Content (VOC): zero (0) g/L.
 - .3 Abrasion Resistance: ASTM D5178-91, CS-17; 75 mg, 1000 g load, 1000 cycles.
 - .4 Tensile Modulus: ASTM D638-86; 950 psi.
 - .5 Tear Strength: ASTM D624 Die C; 220 lb/ In.
 - .6 Elongation: ASTM D638; 115 percent.
 - .7 Water Absorption: ASTM D570; 0.15 percent.
 - .8 Shore A Hardness: ASTM D2240; 99.
 - .9 Water Vapour Permeance: ASTM E96; 0.20 Perm In. (0.0025 ng/ Pa-s-m²).
 - .3 Concrete Repair Material: for cracks, voids, and holes; rapid setting non-shrink grout, as recommended by Durabond Technical Coatings Limited. Reinforcement Mesh: fibreglass woven mesh with alkali resistant latex and polyurethane crack sealant as recommended by Durabond Technical Coatings Limited.
 - .4 Aggregate: clean graded silica by Durabond Technical Coatings Limited.
 - .5 **Sealant:** Sealant Type shall be water resistant, compatible with coating material as recommended by Durabond Technical Coatings Limited and applied in accordance with requirements specified in Section 07 92 00.
- 3 Execution
- 3.1 **EXAMINATION**
- .1 Verify that specified ambient conditions are ensured before commencing work.
 - .2 Test surfaces for moisture content to ensure that they are suitable for application.
 - .3 Ensure that surfaces to receive waterproof floor treatment have been provided as specified in the work of other Sections; that they will not adversely affect execution, permanence, or quality of work; and that they can be put into acceptable condition by means of preparation specified in this Section.

DURABOND TECHNICAL COATINGS LIMITED

The text and format of this guide Specification is provided by Durabond Technical Coatings Limited as information and is Not liable in any way for any revisions or the use of this Guide Specification by any end user. A qualified design professional should review and edit the document to suit project requirements. For more information call Durabond Technical Coatings Limited at 1-877-DURABOND (387-2266).

- .4 Defective work resulting from application to unsatisfactory surfaces will be considered the responsibility of those performing the work of this Section.

3.2 PREPARATION

- .1 Following his acceptance of surfaces, waterproof floor treatment applicator shall be responsible for surface preparation. Prepare concrete floors with commercial shot-blast machine over entire area which receive waterproof floor treatment to minimum ICRI CSP 3.
- .2 Prepare upturns, curbs, surface protrusions, and other areas not accessible with shot blasting equipment using sandblasting equipment or grinding equipment.
- .3 Fill open control joints, and other cracks and voids with material compatible with waterproof floor treatment materials in accordance with ASTM C1127 and as follows.
- .1 Apply waterproof membrane minimum 20 mil thickness for minimum 75 mm each side of unfilled visible cracks up to 1.5 mm and filled cracks in concrete surface including control joints and construction joints to receive coating.
- .2 Apply minimum 0.635 mm thick wet pre-strips of base coat for non-moving joints and cracks less than 1.5 mm wide, fill and overlap joint and crack minimum 75 mm on each side.
- .3 Rout cracks and joints over 1.5 mm wide to minimum 6 mm x 6 mm and blow clean, seal with two component sealant and allow to cure.
- .4 Seal voids with sealant and apply base coat at minimum 25 mils to minimum width of minimum 75 mm on each side of joint.
- .4 Provide sealant cants at rigidly connected wall/curbs/upturns and floor slab junctions. Form sealant cant into corner junction of all horizontal and vertical surfaces (walls/curbs/columns). Lay backer rod into corner and apply 25 mm diameter bead of sealant. Tool to form 45 degree cant. Allow sealant to cure.
- .5 Cover or mask surfaces adjacent to those receiving waterproof floor treatment to protect work of others and property from damage and soil.
- .1 Apply masking tape to vertical surfaces at designed height above sealant cant for clean termination of vertical detail coat. Apply base coat at minimum 25 mils over treated cant up to masking tape and minimum 100 mm onto deck surface. Feather onto deck surface.
- .6 Flashings:
- .1 Provide fluid applied integral flashings at all locations where horizontal surfaces abuts vertical surfaces and all deck projections. Apply waterproof membrane over prepared surfaces at minimum 20 mils and extend minimum 50 mm on vertical surfaces and minimum 100 mm on horizontal surfaces.
- .2 Apply minimum 15 mm sealant bead, tool to form cove, and allow to cure prior to coating at projections including posts, pipes, railings, vents and similar locations of through penetrations.
- .7 Grind down surface irregularities within 1.5 mm of acceptable tolerance.

DURABOND TECHNICAL COATINGS LIMITED

The text and format of this guide Specification is provided by Durabond Technical Coatings Limited as information and is Not liable in any way for any revisions or the use of this Guide Specification by any end user. A qualified design professional should review and edit the document to suit project requirements. For more information call Durabond Technical Coatings Limited at 1-877-DURABOND (387-2266).

- .8 Sweep decks clean of debris and remove standing water.
- .9 Isolate drains, expansion joints, and surface protrusions with saw cut.
- .10 Materials soiled by waterproof floor treatment during application and storage, and from which soil cannot be completely removed, shall be replaced under work of this Section.
- .11 Coordinate scope of work daily to complete sections at natural break points, avoid stop and start lines within a section or panel.
- .12 Mix materials in accordance with manufacturer's recommendations and printed data sheets.

3.3 **APPLICATION - GENERAL**

- .1 Do not apply traffic coating over expansion joints.
- .2 Apply waterproof traffic coating with care to ensure that no laps, voids, or other marks or irregularities are visible, and with an appearance of uniform colour, sheen and texture, all within limitations of materials and areas concerned.
- .3 Match colours and textures of approved samples.
- .4 Make clean true junctions with no visible overlap between adjoining applications of traffic coating.
- .5 Chase edge of traffic coating to finish flush with adjacent floor surface.
- .6 Apply traffic coating over entire floor areas and extend up vertical surfaces such as walls, columns and curbs to a minimum height of {100 mm}[4"].
- .7 Caulk around all pipes and openings made in traffic coating surfaces, with Sealant Type 2, applied in accordance with Section 07 92 00.

3.4 **APPLICATION – WATERPROOF MEMBRANE**

- .1 Apply waterproof membrane with a notched squeegee at uniform thickness of 80 mils DFT. Measure and monitor material application thickness with wet film thickness gauge.
- .2 Allow waterproof membrane to cure for minimum 45 minutes prior to wear course application.
- .3 Do not apply waterproof membrane when relative humidity is above 80 percent or moisture content of concrete is 4 percent by weight of concrete.

3.5 **APPLICATION – WEAR COURSE**

- .1 Application of wear course to follow waterproof membrane installation within minimum 1 hour.
- .2 Apply wear course on waterproof membrane application at minimum thickness of 65 mils in all areas, broadcasting 30-50 mesh silica sand to excess for additional strength. Measure and monitor material application thickness with wet film thickness gauge.
- .3 Non-slip surfaces:

DURABOND TECHNICAL COATINGS LIMITED

The text and format of this guide Specification is provided by Durabond Technical Coatings Limited as information and is Not liable in any way for any revisions or the use of this Guide Specification by any end user. A qualified design professional should review and edit the document to suit project requirements. For more information call Durabond Technical Coatings Limited at 1-877-DURABOND (387-2266).

- .1 Allow wear course to cure for minimum 45 minutes before seal coating.

3.6 APPLICATION – SEAL COAT

- .1 Application of seal coat to follow wear course application within 45 minutes.
- .2 Apply sealcoat with a notched squeegee at uniform thickness of 20 mils DFT. Measure and monitor material application thickness with wet film thickness gauge.
- .3 Non-Slip Surfaces:
 - .1 Broadcast #30-50 mesh silica or aluminium oxide aggregate evenly over surface into wet top coat at minimum 2 – 5 lbs per 100 sq. ft.
 - .2 Allow aggregate/coating matrix to settle, self-level and encapsulate aggregate into coating, back roll surface for smooth consistent finish.
 - .3 Allow wear course to cure for minimum 45 minutes to recoat.
 - .4 Allow sealcoat to cure for minimum 1 hour before allowing traffic.
- .4 Pavement markings: Allow 1 hour for seal coat to cure. Mix pigmentable two component MMA line marking coating in accordance with manufacturer's technical data sheets. Apply uniform coating of line paint to designated areas with 13 mm solvent resistant roller. Allow paint to cure before allowing traffic.

3.7 FIELD QUALITY CONTROL

- .1 **Manufacturer's Field Service:** Traffic Coating manufacturer shall supervise application. Submit reports to Consultant and Contractor on findings of each site visit.

3.8 REPAIR

- .1 Touch-up and refinish minor defective work. Refinish entire coated surface areas where finish is damaged or otherwise unacceptable.

3.9 CLEANING

- .1 Remove promptly as work progresses spilled or spattered materials from surfaces of work performed under other Sections. Clean floors on completion of work. Do not mar surfaces while removing.
- .2 Leave storage and mixing areas in same condition as equivalent spaces in project.

3.10 PROTECTION

- .1 Erect barriers to prevent the entry and presence of persons not performing work of this Section during application of traffic coating, and for 48 hours following completion of application.

END OF SECTION

DURABOND TECHNICAL COATINGS LIMITED

The text and format of this guide Specification is provided by Durabond Technical Coatings Limited as information and is Not liable in any way for any revisions or the use of this Guide Specification by any end user. A qualified design professional should review and edit the document to suit project requirements. For more information call Durabond Technical Coatings Limited at 1-877-DURABOND (387-2266).